



547 HEWETT ST. • P.O. BOX 189
NEILLSVILLE, WI 54456

www.ratschengineering.com

PHONE: 715-743-2240
FAX: 715-743-4469

Addendum Number 3

April 9, 2020

Page 1 of 1

Project:
Proposed Fire Station
Village of Park Ridge
Stevens Point, Wisconsin

Bids Due:
2:00 pm, Monday, April 13, 2020
emailed to kbemowski@park-ridge.us
henry@ratschengineering.com

From:
Ratsch Engineering Company, Ltd.
P.O. Box 189, 547 Hewett Street
Neillsville, WI 54456
Phone: (715) 743-2240
FAX: (715) 743-4469

All bidders are reminded that they must review all plan sheets for work in their bid. Please indicate on the Bid Form that you have received Addendum Number 1, 2 & 3. All bidders shall review the entire addendum.

Please submit your bid on the revised Bid Form.

Bids shall be emailed to both kbemowski@park-ridge.us and henry@ratschengineering.com by 2:00 pm on Monday, April 13, 2020.

Clarifications and changes to the Drawings and Specification

- 1) New breakers in Panel A shall be (1) 400A 2 pole breaker 1 phase, (1) 60A 3 pole 3 phase, and (1) 20A 3 pole, 3 phase breakers.
- 2) acoustical tile to be 2'x2', mineral fiber, rough finish, Cortega by Armstrong or equal.
- 3) Suspended vinyl face sheet rock to be Gridstone vinyl laminated gypsum grid panels or equal.
- 4) Ceiling Grid to be commercial grade, white, Chicago Metallic or equal to be suspended by 9 gauge soft wire. Grid in Shower 109 shall be aluminum.
- 5) Provide owner with extra box of each of the ceiling tiles.
- 6) The scale on the site plan is incorrect. The correct scale shall be 1/16" = 1'-0".

* End of Addendum *